



REVISIONS				
ECO	REV	DESCRIPTION	DATE	APPROVED
0064	0	RELEASE OF DRAWING	10/12/15	BLE
	1	CHANGED FROM TF TO K30 COMP.	04/20/15	BLE

MODEL #	VOLTAGE	HP
NGP-2200D-2B	208 VAC, 3PH, 60HZ	7.5
NGP-2200D-3B	230 VAC, 3PH, 60HZ	7.5
NGP-2200D-4B	460 VAC, 3PH, 60HZ	7.5

NOTES:

- DO NOT ALLOW FUMES TO ENTER COMPRESSOR INTAKE. (SEE INSTRUCTION MANUAL)
- BOLT TO FIRM LEVEL BASE.
- USE BACKUP WRENCH WHEN MAKING CONNECTIONS OR PIPING DAMAGE MAY OCCUR.
- ALL CONNECTING PIPING MUST BE INDEPENDENTLY SUPPORTED AND NOT IMPART STRESS TO COMPRESSOR PACKAGE.
- WIRE COMPRESSOR & PS-1PRESSURE SWITCH TO NITROGEN GENERATOR CABINET. THE MOTOR WIRES CONNECT TO CONTACTOR WITH OVERLOAD. SEE WIRING DIAGRAM.
- ALL WIRING SHOULD BE TO NEC AND APPLICABLE LOCAL STANDARDS.
- DISCONNECT SWITCH SHOULD BE INSTALLED FOR COMPRESSOR.
- PIPE CONDENSATE TO APPROPRIATE DISPOSAL LOCATION.

N:\Work\Engineering\Drawing File\Nitrogen Generators\Non-Certified Versions\NGP 1750, 2200\NGP 2200\DRAWINGS\
G-215326 REV 1 GA, NGP-2200D 7.5 HP Compressor Package

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ARE:			THIS DRAWING AND ALL OF ITS CONTENTS ARE THE SOLE PROPERTY OF GENERAL AIR PRODUCTS, INC. DETAILS MAY CHANGE WITHOUT NOTICE. THE CONTENTS OF THIS DRAWING, MAY NOT BE REPRODUCED OR INCORPORATED IN WHOLE OR IN PART IN ANY EQUIPMENT, NOR THE MANUFACTURE OF ANY PARTS, WITHOUT WRITTEN CONSENT OF GENERAL AIR PRODUCTS, INCORPORATED.		
FRACTIONS	DECIMALS	ANGLES			
± 1"	.XX±X	±X°			

APPROVALS			DATE	TITLE:
DRAWN WLW			10/12/15	NITROGEN GENERATOR GENERAL ARRANGEMENT MODEL NCP-2200D 7.5 HP
CHECKED BLE			10/12/15	
SCALE NONE			SIZE	
SHEET 1 OF 1			B	
DWG. NO.			G-215326	REV 1