





REVISIONS				
ZONE	REV	DESCRIPTION	DATE	APPROVED



MODEL	CONN. "A"	DIM "B"	DIM "C"	DIM "D"	DIM "E"	DIM "F"	DIM "G"	DIM "H"
XPS11E01	1 1/4"	14 "	16 1/2"	21 1/2"	24 1/2"	4.59"	4 3/4"	2.06"
XPS14E03	1 1/4"	14 3/4"	17"	21 1/2"	24 1/2"	4.59"	4 3/4"	2.06"
XPS15E04	1 1/4"	14 1/2"	17"	21 1/2"	24 1/2"	4.59"	4 3/4"	2.06"
XPS18E05	1 1/4"	15 3/4"	18"	21 1/2"	24 1/2"	4.59"	4 3/4"	2.06"
XPS18A04	1 1/4"	15 1/2"	17 3/4"	22 1/2"	25 1/2"	3.25"	5 1/8"	2.06"
XPS19E06	1 1/2"	15 3/4"	18"	21 1/2"	24 1/2"	4.59"	4 3/4"	2.06"
XPS19A06	1 1/4"	15 1/2"	17 3/4"	22 1/2"	25 1/2"	4.50"	5 1/8"	2.06"
XPS19A07	1 1/4"	15 1/2"	17 3/4"	22 1/2"	25 1/2"	3.25"	5 1/8"	2.06"
XPS20E07	1 1/4"	18 7/8"	18"	21 1/2"	24 1/2"	3.50"	4 5/8"	3.50"

NOTES:  
 1-REDUCING THE SUCTION CONNECTIONS TO THE PUMP IS NOT RECOMMENDED. REDUCING SUCTION PIPING MAY LOWER PUMP CAPACITY AND COULD RESULT IN CAVATATION. CAVATATION WILL DAMAGE THE PUMP.  
 2-OVERALL DIMENSIONS ARE FOR REFERENCE ONLY. DIMENSIONS ARE SUBJECT TO CHANGE.

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ARE:  
 FRACTIONS DECIMALS ANGLES  
 ±1/2 .XX ± 1.00° ±1/2'

THIS DRAWING AND ALL OF ITS CONTENTS ARE THE SOLE PROPERTY OF GENERAL AIR PRODUCTS, INC. DETAILS MAY CHANGE WITHOUT NOTICE. THE CONTENTS OF THIS DRAWING, MAY NOT BE REPRODUCED OR INCORPORATED IN WHOLE OR IN PART IN ANY EQUIPMENT, NOR THE MANUFACTURE OF ANY PARTS, WITHOUT WRITTEN CONSENT OF GENERAL AIR PRODUCTS, INCORPORATED.

		TITLE	
		GENERAL ARRANGEMENT RESIDENTIAL FIRE PROTECTION MODESL XPS11,14,15,18,19,20	
APPROVALS	DATE	DWG. NO.	
DRAWN EJR	02-26-10	G-210066	
CHECKED RM	02-26-10	REV	5
SCALE NTS	SIZE D	1 OF 1	