



REV		DESCRIPTION	DATE	APPROVED
ZDNC				

- NOTES:
- 1) MOUNT UNIT TO A FIRM LEVEL BASE, USING SUPPLIED VIBRATION PADS.
 - 2) ACCEPTABLE AMBIENT TEMPERATURE RANGE IS 50 DEG F. TO 100 DEG F.
 - 3) CONNECT CORRECT SUPPLY VOLTAGE TO STARTER LINE TERMINALS IN CONTROL PANEL. POWER SUPPLY VOLTAGE MUST MATCH VOLTAGE ON UNITS MODEL/SERIAL NUMBER LABEL ON THE INSIDE OF THE CONTROL PANEL DOOR.
 - 4) ALLOW CLEARANCE ON ALL SIDES OF DRY AIR PAC FOR MAINTENANCE. MINIMUM CLEARANCE BETWEEN AFTERCOOLER AND WALL IS 12" FOR AIR FLOW.
 - 5) WEIGHT:
 - DAP 1000 = 500 POUNDS SHIPPING = 450 POUNDS NET
 - DAP 2000 = 550 POUNDS SHIPPING = 500 POUNDS NET
 - 6) THE DAP TANK, MOTOR AND COMPRESSOR SYSTEM HAS BEEN TESTED AND COMPLIES WITH CAL OSHA SAFETY ORDERS TITLE 8, PARAGRAPH 462 (L) (2).

GENERAL AIR PRODUCTS		TITLE DAP 1000 AND DAP 2000 DRY AIR PAC ARRANGEMENT	
		APPROVALS DRAWN: EJR CHECKED: DPH DATE: 12-03-07	DATE 12-03-07
DWG. NO. G-207312		REV 0	

UNLESS OTHERWISE SPECIFIED
DIMENSIONS ARE IN INCHES
TOLERANCES ARE:
FRACTIONS DECIMALS ANGLES
±1/4 .XX ±.13 ±1/2

1 OF 1