

REVISIONS			
ECO	REV	DESCRIPTION	DATE
0810	0	RELEASE OF DRAWING	12/19/24
			APPROVED TJK

LEFT TOWER

LEFT TOWER  
PRESSURE GAUGE

RIGHT TOWER

CONTROL BOX

RIGHT TOWER  
PRESSURE GAUGE

COMPRESSOR

FILTER ASSEMBLY

1/2 NPT OUTLET

10 GALLON  
RECEIVER

16.00  
MOUNTING HOLES

PRESSURE  
TRANSDUCER

PRESSURE GAUGE

DRAIN VALVE

VALVE MANIFOLD

- NOTES:
1. MOUNT UNIT TO A FIRM LEVEL BASE, USING SUPPLIED VIBRATION PAD.
  2. ACCEPTABLE AMBIENT TEMPERATURE RANGE IS 50° F TO 100° F.
  3. CONNECT CORRECT SUPPLY VOLTAGE TO STARTER LINE TERMINALS IN CONTROL PANEL. POWER SUPPLY VOLTAGE MUST MATCH VOLTAGE ON UNITS MODEL/SERIAL NUMBER LABEL ON THE INSIDE OF THE CONTROL PANEL DOOR.
  4. ALLOW CLEARANCE ON ALL SIDES OF DRY AIR PAC FOR MAINTENANCE. MINIMUM CLEARANCE BETWEEN AFTERCOOLER AND WALL IS 12" FOR AIR FLOW.
  5. APPROXIMATE WEIGHT: 173 LBS, SHIPPING: 204 LBS
  6. INDOOR USE ONLY


AFTERCOOLER

CHECK VALVE

9.00  
MOUNTING HOLES

UNLESS OTHERWISE SPECIFIED, DIMENSIONS ARE IN INCHES. TOLERANCES ARE:		
FRACTIONS	DECIMALS	ANGLES
±X	.XX ±X	±X°

THIS DRAWING AND ALL OF ITS CONTENTS ARE THE SOLE  
PROPERTY OF GENERAL AIR PRODUCTS, INC. DETAILS  
MAY CHANGE WITHOUT NOTICE. THE CONTENTS OF THIS  
DRAWING MAY NOT BE REPRODUCED OR INCORPORATED  
IN WHOLE OR IN PART IN ANY EQUIPMENT, NOR THE  
MANUFACTURE OF ANY PARTS, WITHOUT WRITTEN  
CONSENT OF GENERAL AIR PRODUCTS, INCORPORATED.

			
APPROVALS	DATE	TITLE:	
DRAWN DL	1/9/2024	GA DAP 500	
CHECKED TK	1/9/2024		
SCALE NONE	SIZE		
SHEET 1 OF 1	B	DWG. NO.	REV
		G-223175	0